



10/21/2019

Work Order: 19J1180
Project: [none]

South Jordan City
Attn: Cary Necaise
10996 S. Redwood Road
South Jordan, UT 84095

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director



Certificate of Analysis

Lab Sample No.: 19J1180-01

Name: South Jordan City	Sample Date: 10/21/2019 10:50 AM
Sample Site: U-111 & Old Bingham	Receipt Date: 10/21/2019 11:23 AM
Comments:	Sampler: Cary Necaise
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH18023
Source Code:	Sample Point:
	Report to State: N

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Hexavalent Chromium	ND		0.01	mg/L	SM 3500 Cr-B	10/21/2019	10/21/2019	



Certificate of Analysis

Lab Sample No.: 19J1180-02

Name: South Jordan City	Sample Date: 10/21/2019 11:00 AM
Sample Site: 4400 W South Jordan Parkway	Receipt Date: 10/21/2019 11:23 AM
Comments:	Sampler: Cary Necaise
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH18023
Source Code:	Sample Point:
	Report to State: N

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Hexavalent Chromium	ND		0.01	mg/L	SM 3500 Cr-B	10/21/2019	10/21/2019	



Certificate of Analysis

Lab Sample No.: 19J1180-03

Name: South Jordan City	Sample Date: 10/21/2019 11:10 AM
Sample Site: Crow Wing	Receipt Date: 10/21/2019 11:23 AM
Comments:	Sampler: Cary Necaise
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH18023
Source Code:	Sample Point:
	Report to State: N

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Hexavalent Chromium	ND		0.01	mg/L	SM 3500 Cr-B	10/21/2019	10/21/2019	



Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

BLANK values in the MCL column indicate no standard.

DRINKING WATER SAMPLES ONLY

CHEMTECH - FORD ANALYTICAL LABORATORY

10/21/19 0 day
RUSH
 Monday
 S-8194, ULINE, 800-295-5510



CHEMTECH-FORD
LABORATORIES

COMPANY: South Jordan City
 ADDRESS: 10996 S. Redwood Road
 CITY/STATE/ZIP: South Jordan City, UT 84095
 PHONE #: _____ FAX: _____
 CONTACT: PROJECT: _____
 EMAIL: cnecaise@sjc.utah.gov

BILLING ADDRESS: _____
 BILLING CITY/STATE/ZIP: _____
 PURCHASE ORDER: _____

TURNAROUND TIME REQUIRED*: _____
 * Expedited turnaround subject to additional charge

CALL

* call Ray first. per Travis. 1Am

18023

Send to State
 Yes No

Please fill in all blue highlighted areas. Must be back at the lab within 24 hours of sampling.

TESTS REQUESTED												Bacteria			LAB FAIL Ref #				
Hexavalent Chromium												Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)	HPC (Plate Count)		R = Routine	I = Investigative	TR = Trigger Source	RP = Repeat
X																			
X																			
X																			

Lab Use Only	CLIENT SAMPLE INFORMATION						
J1180	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine	
-01	U-111 & Old Bingham	10-21-19	10:50	N/A	N/A		X
-02	4400w. South Jordan Pkwy	10-21-19	11:00	N/A	N/A		X
-03	Growing	10-21-19	11:10	N/A	N/A		X

Sampled by: [print] Cary Necaïse Sampled by: [signature] _____
 Special Instructions: _____
 Relinquished by: [signature] _____ Date/Time 10-21-19 11:25
 Relinquished by: [signature] _____ Date/Time _____
 Relinquished by: [signature] _____ Date/Time _____

ON ICE NOT ON ICE Temp (C°): 16.6
 Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.
 Received by: [signature] Annex Mills Date/Time 10/21/19 11:23
 Received by: [signature] _____ Date/Time _____
 Received by: [signature] _____ Date/Time _____

CHEMTECH-FORD
 9632 South 500 West
 Sandy, UT 84070

801.262.7299 PHONE
 866.792.0093 FAX
www.ChemtechFord.com

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).
 Client agrees to pay collection costs and attorney's fees.

